



GENERAL NOTES:

1. SEE CURB DETAIL A-5 FOR CONSTRUCTION OF DEPRESSED CONCRETE CURB AND GUTTER FOR RAMPS.
2. SEE SIDEWALK DETAIL A-2 FOR CONSTRUCTION OF CONCRETE SIDEWALK.
3. SIDEWALK RAMP SHALL BE A MINIMUM OF 4.0-INCHES THICK.
4. SIDEWALK RAMP SHALL BE BROOM FINISHED PERPENDICULAR TO BACK OF CURB.
5. SIDEWALK RAMP SLOPES SHALL BE A MAXIMUM OF 8% (12H:1V).
6. DETECTABLE WARNING AREA SHALL BE CONSTRUCTED OF CAST-IN-PLACE INLINE DOME TACTILE TILE MODULES. THE PATTERN OF THE DOMES SHALL CONFORM TO THE DIMENSIONS SHOWN ON THIS DETAIL.
7. DETECTABLE WARNING AREA SHALL BE YELLOW IN COLOR. THE COLOR SHALL BE AN INTEGRAL PART OF THE MATERIAL AND SHALL NOT BE SURFACE APPLIED.
8. ALL CONSTRUCTION AND MATERIALS SHALL MEET THE SPECIFICATIONS AND BE APPROVED BY THE CITY OF EPHRATA.

| DATE | REVISION | BY |
|--|---|------|
| | | |
| CURB RAMP | | |
| EPHRATA PUBLIC WORKS DEPARTMENT | | |
| CITY OF EPHRATA | | |
| DRAWN |  | A-4A |
| CHECK | | |
| SCALE NTS | | |
| DATE 10/03/08 | | |
| GRANT COUNTY | WASHINGTON | |